



Treating wind farms as individual generators and then convolving them together produces the F_2 curve although the F_1 curve is the total hourly wind MW duration curve. Both Monte Carlo and Analytical methods suffer this problem when we treat renewables as generators rather than load reducers.